

Number	18-000501-PR01 (NW-D02-05-en-01)
Owner	BLASI GmbH Carl-Benz-Str. 5-15 77972 Mahlberg Germany
Product	
Designation	System: BLASI 30 Shipping name: record CURVED Standard 180
Details	Manufacturer BLASI GmbH, - Mahlberg ; Material Aluminium ; Attackside: Outside of building ; Dimensions: Ø 2800 mm x 3000 mm ; Glazing: Classe P4A as per DIN EN 356 ; Locking: MPV20-2 / Agtatec ; Rollers: 2 Stk. P1490 / Fa. BLASI GmbH ; anti-lift device: 5 pcs. aluminum plates; 2 pcs. plastic blocks
Special features	

Result

Burglary resistance according to EN 1627:2011-05



Class: RC 2

Basis *)

EN 1627:2011-05

*) and corresponding national versions
e.g. DIN EN

Test report: 18-000501-PR01 PB-D02-05-de-01

Representation



Instructions for use

The results obtained apply to the field of extended application as set out in EN 1627, Annex D.

Validity

There is no time limit.


When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

11.09.2018



Florian Willer, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Security/Safety Testing



Fabian Kutscher, Dipl.-Ing. (FH)
Operating Testing Officer
Security/Safety Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: D04-59003